

PREVENTATIVE MAINTENANCE MANUAL

Department:	Sewer	Map:		E Jefferson St		
Unit:	-Lift Station]		Legal	•	0
Job:	Daily Operation Insp]		35.95287 -97.5	57596	Av
Purpose:	Inspection / Log	Location:		Jefferson east past ball field to en	o end	
Frequency:	Daily			of road.		
Objective:	Record pump & grinder operating times. Visually inspect generator, flow meter, grinder & bypass grate, lift pumps 1 & 2.					
Tools Required:	Control room lock code: 111 Equipment lock code: 253	1				
Procedure:	 Record Lift Pump 1 & 2 times. Record Sewer Chewer time & reverse cycles. Record Generator time. (Note if time has increased, indicating run hours) Verify diesel fuel level is full. Verify run switch is set to AUTO Inspect flow meter & channel is clear and sewage is flowing freely. Inspect grinder for obstructions, blockages, noises, vibration. Inspect bypass flow grate for debris, ensure flow path is clear. Verify flow path gate is secure and note flow path. Verify wet sump is flowing and observe at least 1 complete pump cycle. Inspect yard for weeds and debris. If maintenance is required and cannot be completed while you are onsite, send maintenance request on Teams to PWA channel: Operations & Reports. Lock all doors and return to service. 					
More Info:	http://cityofcrescent.com/pm	1234	L	ast Updated:	08/18/18	